

GENERAL DEVELOPMENT UTILITIES, INC.  
PORT LABELLE DIVISION

EXHIBIT "A"

SCHEDULE OF DAILY RATED GALLONAGE  
FOR VARIOUS OCCUPANCIES

Types of Building Usage

Apartments . . . . .	250 gpd(1)
Bars and Cocktail Lounges . . . . .	5 gpcd (2)
Boarding Schools (students and staff) . . . . .	75 gpcd
Bowling Alleys (toilet wastes only, per lane) . . . . .	100 gpd
Country Clubs (per member) . . . . .	25 gpcd
Day Schools (students and staff) . . . . .	10 gpcd
Drive-in Theatres (per car space) . . . . .	5 gpd
Factories (with showers) . . . . .	30 gpcd
Factories (without showers) . . . . .	10 gpd/100 sq. ft
Hospitals (with laundry) . . . . .	250 gpd/bed
Hospitals (without laundry) . . . . .	200 gpd/bed
Hotels and Motels . . . . .	200 gpd/rm or unit
Laundromats . . . . .	225 gpd/washer
Mobile Home Parks . . . . .	350 gpd/trailer
Movie Theatres, Auditoriums, Churches (per seat) . . . . .	3 gpd
Nursing Homes . . . . .	150 gpd/100 sq ft
Office Buildings . . . . .	10 gpd/100 sq ft
Public Institutions (other than those listed herein) . . . . .	75 gpcd
Restaurants (per seat) . . . . .	50 gpcd
Single-Family Residential	
Water: 5/8 x 3/4" meter . . . . .	350 gpd
1" meter . . . . .	875 gpd
1 1/2" meter . . . . .	1,750 gpd
Sewer . . . . .	200 gpd
Townhouse Residences . . . . .	250 gpd
Stadiums, Frontons, Ball Parks, etc (per seat) . . . . .	3 gpd
Stores (without kitchen wastes) . . . . .	5 gpd/100 sq ft
Speculative Buildings . . . . .	30 gpd plus 10 gpd/100 sq ft
Warehouses . . . . .	30 gpd plus 10 gpd/1000 sq ft
Other . . . . .	gpd 350

(1) gpd - gallons per day

(2) gpcd - gallons per capita per day

NOTE: Gallonage refers to flow on a unit basis for average daily flow in gallons per day.

CHARLES E. FANCHER, JR.  
PRESIDENT

Florida Public Service Commission


APPROVED

Authority No. WS-92-0302

Docket No. 921235-WS

Order No. PSC-93-1440-FOF-WS

Effective December 6, 1993



Director  
Division of Water and Wastewater