



2-17 #651
PORT LABELLE UTILITY SYSTEM

P. O. Box 2340 · 3130 Utility Drive · LaBelle, FL 33975
Telephone: (863) 675-8376 Fax: (863) 675-1282

February 8, 2008

41
John Capece
Villa 18 Marina Drive
LaBelle, FL 33935

SUBJECT: Lead & Copper Test Results

We have received the results from our recent Lead & Copper Sampling and are pleased to report all samples taken in December 2007 were satisfactory and well below the maximum contaminate levels.

The Action level for Leas is 0.015 mg/L and 1.3 mg/L for Copper

Your results were:

Lead 0.002 mg/L # 300003
Copper 0.09 mg/L

Another set of samples will need to be collected in a few weeks. Your assistance in this process is greatly appreciated.

Sincerely,

Roger B. Greer
Utility Director
3130 Utility Drive
P.O.Box 2340
LaBelle, FL 33975